

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0895:110

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Linear Corporation, 2055 Corte Del Nogal, Carlsbad, CA 92009
Contact: John Kuivinen (760) 438-7000 x 227

DESIGN: Models DF-16 and DF16PA receivers with Model DF-10 wireless keystation. Unit is a residential security receiver system intended for use with separately listed *Models DF-72, DXT-72 (CSFM Listing No. 7257-0895:106) single station smoke detector as an accessory. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke detector accessory for use with listee's smoke detectors listed above. For indoor use only.

NOTE: Models DF-16 and DF16PA are NOT fire alarm control units.

*Rev. 06-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 19, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager